



Reference No.: (OTHR)485-AP/485/2026/09

URA Weekly Water Quality Report - Week 2, August 2026

		Reference Units	6.5 - 8.5	<1000 µS/cm	<1 NTU	<500 mg/L	0 CFU/100 mL	0 CFU/100 mL
Location	Prepared by	Checked by	pH	Conductivity	Turbidity	TDS	Total Coliform	E-Coli
Male'			7.01	627	0.045	326	0	0
Hulhumale'			6.67	497	0.048	253	0	0
Villimale'			7.18	616	0.052	316	0	0
K. Huraa			6.87	427	0.262	220	0	0

Approved by

HOD / Director

Service Quality and Assurance Section



Utility Regulatory Authority
Kaasinjee Magu, Henvairu, Male', 20044,
Male', Republic of Maldives.

20044



+960 333 2488



www.ura.gov.mv



secretariat@ura.gov.mv



Reference No.: (OTHR)485-AP/485/2026/10

URA Weekly Water Quality Report - Week 3, August 2026

		Reference Units	6.5 - 8.5	<1000 $\mu\text{S}/\text{cm}$	<1 NTU	<500 mg/L	0 CFU/100 mL	0 CFU/100 mL
Location	Prepared by	Checked by	pH	Conductivity	Turbidity	TDS	Total Coliform	E-Coli
Male'			7.18	669	0.161	346	0	0
Hulhumale'			6.95	491	0.066	247	0	0
Villimale'			7.48	660	0.052	332	0	0
K. Huraa			6.9	434	0.136	225	0	0

Approved by



HOD / Director

Service Quality and Assurance Section





Reference No.: (OTHR)485-AP/485/2026/11

URA Weekly Water Quality Report - Week 4, August 2026

		Reference Units	6.5 - 8.5	<1000 $\mu\text{S}/\text{cm}$	<1 NTU	<500 mg/L	0 CFU/100 mL	0 CFU/100 mL
Location	Prepared by	Checked by	pH	Conductivity	Turbidity	TDS	Total Coliform	E-Coli
Male'			7.15	662	0.051	344	0	0
Hulhumale'			7.02	495	0.047	251	0	0
Villimale'			7.24	652	0.050	340	0	0
K. Huraa			6.99	461	0.151	235	0	0

Approved by



HOD / Director

Service Quality and Assurance Section



