



Reference No.: (OTHR)485-AP/485/2026/2

URA Weekly Water Quality Report - Week 4, June 2026

		Reference Units	6.5 - 8.5	<1000 $\mu\text{S}/\text{cm}$	<1 NTU	<500 mg/L	0 CFU/100 mL	0 CFU/100 mL
Location	Prepared by	Checked by	pH	Conductivity	Turbidity	TDS	Total Coliform	E-Coli
Male'			6.84	632	0.042	316	0	0
Hulhumale'			6.8	492	0.061	246	0	0
Villimale'			7.33	616	0.046	317	0	0
K. Huraa			5.72	480	0.047	248	0	0

Note: Low pH of K. Huraa was identified and necessary actions were taken to rectify the issue.
The issue has since been resolved

Approved by



HOD / Director

Service Quality and Assurance Section

