







Reference No.: (OTHR)485-AP/485/2026/6

URA Weekly Water Quality Report - Week 4, July 2026

		Reference Units	6.5 - 8.5	<1000 µS/cm	<1 NTU	<500 mg/L	0 CFU/100 mL	0 CFU/100 mL
Location	Prepared by	Checked by	pH	Conductivity	Turbidity	TDS	Total Coliform	E-Coli
Male'			7.17	683	0.053	350	0	0
Hulhumale'			6.75	450	0.056	252	0	0
Villimale'			7.06	631	0.045	317	0	0
K. Huraa			6.75	415	0.092	212	0	0

Approved by

Approved _____

HOD / Director

Service Quality and Assurance Section



Utility Regulatory Authority

Kaasinjee Magu, Henveiru, Male', 20044,
Male', Republic of Maldives.

20044



+960 333 2488



www.ura.gov.mv



secretariat@ura.gov.mv